

## Service Report

Date: 26<sup>th</sup> March 2025


To,  
Nirankari Education Society 's  
Priyadarshani English Medium school  
Wadgoan Road, Near Ram Mandir,  
Charholi Khurd, Alandi Devachi,  
Tal- Khed, Pune- 412105.  
Mob- 9372140844

No	Description (Location) of Tank	Cleaned On (Date)	Time
1	All Water Storage Tanks in Above Premise	26 <sup>th</sup> March 2025	10.00am-5.30pm

All the tanks were cleaned by following the SOP (Standard Operating Procedure). There was no any physical damage to the cleaned particulars & the Tanks were cleaned to the satisfaction level of Supervisor.

Thank you for giving us the opportunity to serve you. We appreciate your business and the confidence you have placed in us. Please call us if we can be of further assistance.

Thanks, and Regards



Aquatech Water Tank Cleaning Services

## Service Report

Date: 27<sup>th</sup> March 2025


To,  
Nirankari Education Society's  
Priyadarshani English Medium school  
Wadgoan Road, Near Ram Mandir,  
Charholi Khurd, Alandi Devachi,  
Tal- Khed, Pune- 412105.  
Mob- 9372140844

No	Description of Service	Service Date	Time
1	Fumigation For Mosquitoes and general Pest Treatment	27 <sup>th</sup> March 2025	10.00am-1.30pm

Complete Premise at mentioned above address treated with **DeltaFog™** –  
With Fogger & **Diversey Virex 2 256** Solution with ULV Cold Fogger as per the  
SOP (Standard Operating Procedure) Attached to this Report

Thank you for giving us the opportunity to serve you. We appreciate your  
business and the confidence you have placed in us. Please contact us if we can be  
of further assistance.

Thanks, and Regards



**Aquatech Water Tank Cleaning Services**



GOVT. OF MAHARASHTRA

**DEPUTY DIRECTOR, HEALTH SERVICES**  
**STATE PUBLIC HEALTH LABORATORY, PUNE.**  
 Near St. Mary School And Church, Pune 411001

Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com



HEALTH SERVICES

NO. SPHL PUNE /Desk -79 / 519 / 2025. DATE :- 05/05/2025.

## Report on Chemical Analysis of Drinking Water

Sent by :- Priyadarshani English Medium School, Alandi devachi Pune.

With Ref. letter No :- --

Dated :- 27/03 /2025

Date of Collection :- ----

Date of Receipt :- 27/03/2025

Date of Examination :- 29/ 03/ 2025 onwards

(All the Analytical Results are in mg. / Lit, except pH, Turbidity)

SR. NO	TEST PARAMETER	S.No. - I (P-519) Well -Filter Water	BIS Specifications 10500 : 2012 Normal Values	
			Desirable limit	Permissible limit
1	Physical Appearance	Slight turbid with suspended matter.	---	---
2	Odour	agreeable	agreeable	agreeable
3	Turbidity ( as N.T.U. )	2.03	1.0	5.0
4	pH Value	7.07	6.5 to 8.5	No relaxation
5	Chlorides ( as Cl )	14.89	250	1000
6	Nitrates ( as No3 )	1.07	45	No relaxation
7	Total Hardness ( as Caco3 )	15.82	200	600
8	Alkalinity ( as Caco3 )	22.29	200	600
9	Total Dissolved Solids	49.0	500	2000
10	Iron ( as Fe )	ND	1.0	No relaxation
11	Fluoride ( as F )	ND	1.0	1.5

- ND :- Not detected.
- This report is restricted only for the sample /s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.
- This Sample /s is /are not collected by this laboratory.

**Remark :-** Water Sample. 1 Contains Turbidity more than desirable limit 1.0 N.T.U. resp as per BIS Specifications 10500 : 2012.

However, if there is no any other alternate source available near by then this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining it's bacteriological quality frequently or regularly.

Forwarded with compliments to :- Priyadarshani English Medium School, Alandi devachi Pune.

Fees	600 /-
Receipt No.	5119593
Date	05/05/2025

*Paikwa*  
 Senior Scientific Officer  
 State Public Health Laboratory  
 Pune-411 001